

建筑安装用接线端子 Installation terminal blocks



RL35I



端子厚度 / 宽度 (mm): 15.2 / 55
高度 (TH35-7.5 / TH35-15 / G32) (mm): 51 / 58.5 / 56

IEC 数据	IEC Data	刚性导线 Rigid mm ²	柔性导线 Flexible mm ²	AWG kcmil	I A	U V
IEC 60947-7-1	IEC 60947-7-1	0.75-35	0.75-35	18-2	125	800
过电压类别	Overvoltage Category	(-)		III		
额定冲击电压	Rating impulse voltage	(KV)		8		
污染等级	Pollution degree	(-)		3		
绝缘材料组别	Insulating Material Group	(-)		I		
绝缘材料	Insulating Material	(-)		PA		
材料阻燃等级 UL94	Flammability class UL94	(-)		V2		
螺钉 / 扭矩	Screw/Torque	(-Nm)		M6 / 3.2-3.7		
剥线长度	Stripping length	(mm)		16		
UL 数据	UL Data					
额定电压 / 电流	Rate Voltage / Current	(V / A)		600 / 115		
压线范围	Wire Range	(AWG)		18-2		

配件	Accessories	型号 mode	定货号 order number
1. 端盖, 厚 1.8 mm	End Cover: thickness 1.8 mm	-	-
2. 中心联络件: 用于端子中央, 实现横向桥接, 螺钉头带绝缘圈, 桥接前需将外壳的隔片打通	Middle Bridge: for cross connections, screw heads with insulating collar, first remove partition plate	JFB2-35 JFB3-35	5585162 5585163
3. 侧边联络件: 全绝缘, 插入压线框中, 并卡在端子的绝缘外壳上	Insertion bridge: full insulation, is laid into terminal sleeve and snap fitted into the terminal housing	JEB10-35	5582150
4. 绝缘隔片: 用于相邻联络件间的电气隔离; 可事后插入; 不占导轨的任何空间	Separating Disk: for electrical separation of neighboring adaptors; can be fitted later, no loss of pitch cross section.	JS-K	8751102
5. 分组隔板: 用于端子组间的视觉及电气隔离; 厚 1.5 mm	Partition Plate: for visual and electrical separation of terminal groups	-	-
6. 测试插座: 与测试插头形成测试连接	Test socket: to form a testing connection by using test plug	PSB6/5/6	8573103
7. 测试插头: 与测试插座形成测试连接	Test plug: to form a testing connection by using test socket	PS	5553102
8. 标记条: 有横向和竖向两种字体, 10 位	Marker Strip: with horizontal and vertical word, 10 spaced	ZB10	8868105
9. 警示牌	Warning board	JW15	8867106